

ComEd Plans for Reliability Improvements in Village-Identified Priority Circuits						
Circuit Number	Circuit Location	Total Outages 2007 - 2010	Recent Reliability Improvements Completed by ComEd	Reliability Work Planned by ComEd	Target Completion Date	Actual Completion Date
W8017	Area west of Main Street on the north and south side of Maple Ave. It includes the Denburn Woods neighborhood and the area around the intersection of Dunham and Blanchard.	77	2010 - Installed Distribution Automation Device N/59th, E/Woodward 2010 - Replaced three poles and upgraded lightning protection	Perform "enhanced tree trimming" in the following areas: - S/ Maple Ave., between Middaugh Ave and Carpenter St - N/55th between Brookbank Rd. and Carpenter St. - S/Maple Ave, between Woodard Rd. and Sherman Ave. - 55th St. between Lyman St. and Main St. • Replace equipment in the following areas: - Install 1,400' of single phase Hendrix Cable (S/55th St. W/Middaugh Ave)	Equipment Upgrades by June 2012; Tree trimming by end of first quarter 2012	
W4572	Area near the intersection of Fairview and Ogden, primarily the south side of Ogden west of Cumnor but also extending north along Fairview.	62	2009 – Installed Distribution Automation Device on Fairview between Ogden Ave and Grant St	W4572 • Perform "enhanced tree trimming" in the following areas: - Meyers Rd between White Oak Lane and 35th St - S/Ogden between Washington St. and Elm St. • Replace equipment in the following areas: - Replace 500' of underground cable W/School St. S/Herbert St.	Equipment Upgrades by June 2012; Tree trimming by end of first quarter 2012	
W031	Located between Ogden and Maple from I-355 to Main Street	62	2010 – Installed Distribution Automation Device N/Burlington, E/Carpenter St 2010 – Installed Distribution Automation Device on Ogden, E/Finley Rd	• Perform "enhanced tree trimming" in the following areas: - Gilbert Ave and Carpenter St.	Tree trimming by end of first quarter 2012	
W039	Area to the northwest of Downers Grove South High School	60	2007 – Replaced Underground Cable from I-355 to Walnut Ave 2010 – Installed Distribution Automation Device on College Road 2010 – Upgraded lightning protection at 63rd and Stonewall	Perform "enhanced tree trimming" in the following areas: - N/Maple Ave. between Walnut Ave. and Lomond Ave. - S/59th between Belmont Rd. and Pershing Ave.	Tree trimming by end of first quarter 2012	
W4101	Area northwest of the corner of Ogden and Main Street, including a portion of the Orchard Brook subdivision	59	2008 – Replaced underground cable from Venard to Saratoga 2009 – Installed Hendrix cable near Bellaire Lane and Rove Ave 2009 – Installed Distribution Automation Device on 41st St and Forest Ave 2010 – Upgraded lightning protection (W/Venard and N/Ogden)	No major reliability impact items identified as a result of this pocket reliability analysis	N/A	N/A

W455Y	Northern end of the Village west of Highland Avenue and extending up to I-88	55	2010 – Replaced underground cable from Pomeroy to Barberry Ct	Perform “enhanced tree trimming” in the following areas: <ul style="list-style-type: none"> – N/35th St between Saratoga Ave and Highland Ave • Replace equipment in the following areas: – Install 3,600’ of single Hendrix Cable N/35th St. W/Highland Ave. 	Equipment Upgrades by June 2012; Tree trimming by end of first quarter 2012	
W036	Area south of Burlington to 59th Street, between I-355 and Fairview	52		Perform “enhanced tree trimming” in the following areas: <ul style="list-style-type: none"> – S/Randall St. between Benton Ave. and Blodgett Ave. 	Tree trimming by end of first quarter 2012	
W0325	Area between Chicago and Ogden, as well as the northern part of the Downtown.	46	2007 – Installed 670’ of Hendrix Cable W/Linscott Ave, between Prairie and Chicago 2007 – Installed Distribution Automation Device on Chicago Ave, W/Highland Ave	Perform “enhanced tree trimming” in the following areas: <ul style="list-style-type: none"> – W/Linscott Ave., between Chicago Ave. and Lincoln Ave. – E/Forest Ave. between Lincoln St. and Prairie Ave. 	Tree trimming by end of first quarter 2012	
W8011		44	2010 – Replaced underground cable (600’) from Main St. to Lancaster Ave 2010 – Re-tension reduced tension span (S/63rd St between Barrett and Saratoga)	Perform “enhanced tree trimming” in the following areas: <ul style="list-style-type: none"> – W/Main St. between Palmer St. and 67th St. – N/S 62nd Pl. W/Carpenter St. • Replace equipment in the following areas: – Replace underground cable (500’) E/Main St. between Lancaster Ave. and Bonnie Brae Ave. – Install 700’ single phase Hendrix Cable N/62nd PL. W/Carpenter St. 	Equipment Upgrades by June 2012; Tree trimming by end of first quarter 2012	
W803		43	2009 – Replaced underground cable 4,800’ from Stonewall to Dunham Rd	No major reliability impact items identified as a result of this pocket reliability analysis	N/A	N/A

ComEd Plans for Reliability Improvements in ComEd-identified Priority Circuits		
Circuit	ComEd Plans for Reliability Improvements	Target Completion Date
W458X	Perform "enhanced tree trimming" in the following areas: - Meyers Rd. from I-88 to 35th St - 35th St. to Douglas Rd. - Douglas Rd. to N/Ogden Ave - N/Ogden Ave. to Cumnor Rd	By the end of the first quarter of 2012
W8013	Perform "enhanced tree trimming" in the following areas: - South of 59th between Blodgett Ave and Osage Ave	By the end of the first quarter of 2012
W0318	Perform "enhanced tree trimming" in the following areas: - Prairie Ave between Cornell and Lee Ave.	By the end of the first quarter of 2012